



Akhtar, R., Draper, E. R., Adams, D. J. and Hay, J. (2018) Oscillatory nanoindentation of highly compliant hydrogels: a critical comparative analysis with rheometry. *Journal of Materials Research*, 33(8), pp. 873-883.

There may be differences between this version and the published version. You are advised to consult the publisher's version if you wish to cite from it.

<http://eprints.gla.ac.uk/161532/>

Deposited on: 30 April 2018

Enlighten – Research publications by members of the University of Glasgow_
<http://eprints.gla.ac.uk>

Oscillatory nanoindentation of highly compliant hydrogels: A critical comparative analysis with rheometry

Riaz Akhtar^{a)*}, Emily R. Draper^{b)}, Dave J. Adams^{b)} and Jennifer Hay^{c)}

a) Department of Mechanical, Materials and Aerospace Engineering, School of Engineering, University of Liverpool, L69 3GH, United Kingdom

b) School of Chemistry, WESTChem, University of Glasgow, Glasgow, G12 8QQ, United Kingdom

c) Nanomechanics Inc, 105 Meco Ln, Oak Ridge, TN 37830, USA

*Corresponding author: r.akhtar@liverpool.ac.uk

Abstract

We present a method for measuring the shear complex modulus of hydrogels by oscillatory nanoindentation, with unprecedented attention to procedure and uncertainty analysis. The method is verified by testing a typical low-molecular-weight gelator (LWMG) formed from the controlled hydrolysis of glucono- δ -lactone (GdL). Nanoindentation results are compared with those obtained by rheometry using both vane-in-cup and parallel-plate fixtures. At 10Hz, the properties measured by oscillatory nanoindentation were $G' = 38.1 \pm 2.8$ kPa, $\tan \delta = 0.22 \pm 0.02$. At the same frequency, the properties measured by rheometry were $G' = 15.3 \pm 2.9$ kPa, $\tan \delta = 0.11 \pm 0.016$ (vane-in-cup) and $G' = 7.9 \pm 1.1$ kPa, $\tan \delta = 0.05 \pm 0.004$ (parallel-plate). The larger shear modulus measured by nanoindentation is due to the scale of testing. Whereas rheometry characterizes the bulk material response, nanoindentation probes the fibrous network of the gel. The procedure and analysis presented here are valuable for nanoindentation testing of other compliant materials such as hydrogels, soft biological tissue and food products.

I. Introduction

Nanoindentation is a well-developed technique for measuring the mechanical properties of stiff materials. There is growing interest in using the technique for determining the properties of more compliant materials¹ including biological tissues²⁻⁴ and hydrogels⁵⁻⁷.

The advantages of using a nanoindenter instead of more conventional techniques include the ability to probe small volumes of tissue and the ability to spatially resolve the properties of the material. The latter is particularly important, given that biological materials or hydrogels may not have homogeneous microstructures^{8,9} or may have been designed to have spatially varying properties.¹⁰

One of the key developments in nanoindentation is the ability to conduct oscillatory tests. This method superimposes an oscillating force and measures the resulting indenter oscillation amplitude and phase shift. The analysis to derive contact stiffness and damping is straightforward if the indentation system is well modeled as a simple-harmonic oscillator, both prior to, and during, sample contact.¹¹⁻¹⁴ Such testing enhances instrumented indentation as a materials characterization tool. Of relevance to the present work is the ability to measure the viscoelastic properties of a material at a series of specific frequencies.

Many studies have compared oscillatory nanoindentation data with macro-scale dynamic test methods, including dynamic mechanical analysis (DMA), dynamic mechanical thermal analysis (DMTA) and rheometry. These macro-scale methods have a long history and thus serve to validate nanoindentation methods. Early work by White et al. compared rheometry with oscillatory nanoindentation for epoxy, PMMA and two types of PDMS of differing moduli.¹⁵ The complexity of a direct comparison was evident as each sample had to be tested by a different mode with the rheometer, due to differing sample geometries and

instrument compliance. For the epoxy resin, nanoindentation values were found to be lower than the rheometric values by a factor of two; agreement was better for the PMMA. For the PDMS samples, good agreement was found for the stiffer sample, but for the most compliant sample (storage modulus of approximately 1 MPa), the nanoindentation values were significantly higher than rheometric values. Generally, the discrepancies were attributed to delayed surface detection, insufficient knowledge of contact area, and inherent differences in strain and strain rate between the two methods. In another work, Hayes et al.¹⁶ compared oscillatory nanoindentation with DMTA to determine the properties of four different polymers and found good agreement in $\tan \delta$ (the ratio of loss modulus to storage modulus, also known as the “loss factor”). However, storage and loss moduli from the nanoindenter were not reported due to substantial errors in contact area.¹⁶ We note here that the nanoindentation loss factor is immune to errors in contact area, because both the loss modulus and storage modulus depend on contact area in the same way, making their ratio independent of contact area.

One of the issues with many of the earlier studies using nanoindentation to test compliant materials was the use of pyramidal indenters such as the Berkovich tip. Such an indenter causes a contact that violates the conditions of linear viscoelasticity, which is the basis on which rheological measurements of polymers are conducted.^{17, 18} Herbert et al. demonstrated that a frustum indenter (a flat-ended cylinder) can preserve linear elasticity, if the penetration depth is small.¹⁷ Further, with a frustum, the contact area is known and constant throughout the experiment; it is simply the area of the circular end. Herbert et al. also carefully characterized the dynamic response of their nanoindentation instrument to accurately isolate the contribution of the contact. With these improvements to the nanoindentation method, they demonstrated good agreement between nanoindentation and dynamic mechanical analysis (DMA) on highly plasticized polyvinyl chloride (PVC) over the frequency range of 1 to 50 Hz. Following this, others have found general agreement between oscillatory nanoindentation and

DMA.¹³ Consequently, oscillatory nanoindentation has now gained acceptance as a way to make small-scale DMA measurements, even though discrepancies remain due to fundamental differences in imposed strain and strain rate.¹⁹ However, for materials that are so compliant that they are normally tested with a rheometer, making comparable measurements by oscillatory nanoindentation remains challenging, but highly desirable. Recently, oscillatory nanoindentation methods have been utilized to study soft tissues²⁰⁻²² and also hydrogels.²³

In this study, our interest is in the application of oscillatory nanoindentation to a class of highly compliant hydrogels which are known as low-molecular-weight gelators (LMWGs).⁹ ¹⁰ LMWGs are an interesting class of molecule that can self-assemble under specific conditions to form a hydrogel.²⁴ The challenges of utilizing oscillatory nanoindentation for such materials is two-fold. Firstly, the compliance of the material means that the measured contact stiffness can be on the order of the uncertainty in the stiffness, thus making uncertainty analysis an essential aspect of experimental design. Secondly, the bulk methods of characterization often differ widely, as demanded by the properties of the sample. For samples having moduli on the order of kPa, simple parallel-plate rheometry may be used. For even more compliant samples, a vane-in-cup form of rheometry is more suitable, wherein the vane consists of four or more cross-shaped blades at the end of a central shaft which can be inserted into the gel with little disruption of its microstructure.²⁵ To the best of our knowledge, there has not been a systematic study which examines the application of oscillatory nanoindentation to LMWGs with a direct comparison to rheometry.

Here, we compare oscillatory nanoindentation to both parallel-plate and rotational (vane) rheometry of LMWGs. In particular, we focus here on LMWGs formed using a pH trigger that arises from the controlled hydrolysis of glucono- δ -lactone (GdL) to gluconic acid⁹ due to the reproducibility of this gelation method. It is well-established that pH-triggered LMWGs, including those formed using GdL, exhibit mechanical behavior which is governed

by the fibrous microstructure of the gels.²⁶⁻²⁸ A number of factors affect the mechanical properties of the gels including the final pH of the gel and the rate of pH change during gel formation.⁹ The rheological behavior is well-described in the literature for LMWGs.²⁹ With strain, G' and G'' are constant at low strain, but at higher strains, G' decreases sharply due to a breakdown in the gel network. With frequency, properties are relatively constant below about 15 Hz.⁹ Properties also depend on strain rate. For unconfined low-speed compression (1 mm s^{-1}), the gels exhibit a plastic response which is coupled with expulsion of water from the gel. For high-speed compression (5 mm s^{-1}), the gels have an initial elastic response that is consistent with the shear rheology results, followed by a brittle failure at around 3-5 % strain.²⁶ Samples produced by the GdL gelation method are ideal for investigating the utility of oscillatory nanoindentation as an alternative technique to bulk characterization via rheometry. Firstly, GdL hydrolysis results in homogenous hydrogels which are not affected by the shear or mixing history.⁹ Secondly, as stated above, the mechanical behavior of gels formed by this method is well-characterized, especially with vane-in-cup rheometry. Thirdly, their microstructure can easily be determined with complementary techniques such as optical imaging and scanning electron microscopy.⁹ Fourthly, due to their compliance, they serve as an ideal candidate for exploring issues around uncertainty in the instrumentation.

II. Theory of oscillatory nanoindentation for rheological properties

This section provides a theoretical overview of the oscillatory nanoindentation method that has been utilized in this study.

A. Oscillatory indentation (theory)

The theory of oscillatory indentation is informed both by elastic contact models and constitutive forms used to comprehend the mechanical behavior of polymers. Sneddon was the first to derive a general relation between force, displacement, and shear modulus for an axisymmetric indenter in contact with a flat surface.³⁰ Oliver, Pharr, and Brotzen showed that a derivative form of Sneddon's relation is largely independent of the geometry of the indenter³¹ This derivative relation is

$$G' = S(1-\nu)/(4a) \quad (1)$$

where G' is the shear storage modulus of the material, ν is the Poisson's ratio, S is the elastic stiffness of the contact and a is the radius of contact, or the simply the radius of the punch face, if using a frustum. If the material response is substantially elastic, then G' is identical to the shear modulus, G . Also, for gels and biomaterials, it is reasonable to assign $\nu = 0.5$ ^{32, 33}, leading to

$$G' = S/(8a). \quad (2)$$

Later, Loubet, Lucas, and Oliver invoked the Kelvin-Voigt material model and thereby deduced the analogous relationship³⁴

$$G'' = D_s\omega/(8a), \quad (3)$$

where G'' is the loss modulus and $D_s\omega$ is the contact damping, manifest as the damping coefficient D_s multiplied by the radial frequency, ω . The loss factor, $\tan \delta$, defined as the loss modulus divided by the storage modulus is

$$\tan \delta \equiv G''/G' = D_s\omega/S. \quad (4)$$

Thus, the task of measuring the complex modulus of a polymer by oscillatory indentation is that of measuring the contact stiffness, S , and contact damping, $D_s\omega$.

The indentation system utilized in this study has been deliberately designed to behave as a simple-harmonic oscillator, so that by oscillating the system with a force amplitude, F_0 , and

angular frequency, ω , and measuring the resulting displacement amplitude, z_0 , and phase shift, ϕ , we may know the values of all the components of the oscillator: K , D , and m . Specifically,

$$K - m\omega^2 = (F_0/z_0)\cos \phi = \kappa, \text{ and} \quad (5)$$

$$D\omega = (F_0/z_0)\sin \phi = \chi. \quad (6)$$

When the indenter is free-hanging, or not in contact with any material, then K , D , and m are the stiffness, damping, and mass of the indentation system alone, or K_i , D_i , and m_i . In fact, this is how K_i , D_i , and m_i are determined: by oscillating the indenter when it is free-hanging. When the indenter is in contact with a test material, the parameters K , D , and m comprehend the combined effect of both the indentation system *and* the contact. Thus, the fundamental values of F_0 , z_0 , and f must be compensated for the known influence of the instrument in order to isolate the contact. During an experiment, we obtain the contact stiffness for use in Eq. 2 as the combined dynamic stiffness less the instrument stiffness, or

$$S = (F_0/z_0)\cos \phi - (K_i - m_i\omega^2) = \kappa - \kappa_i \quad (7)$$

and we obtain the contact damping for use in Eq. 3 as the combined dynamic damping less the instrument damping, or

$$D_s\omega = (F_0/z_0)\sin \phi - D_i\omega = \chi - \chi_i \quad (8)$$

B. Uncertainty analysis (theory)

Some of our experimental choices, namely testing frequency and punch size, were guided by uncertainty analysis. The relative uncertainty in shear storage modulus is dominated by the relative uncertainty in contact stiffness,

$$\delta G'/G' = \delta S/S, \quad (9)$$

and likewise for the shear loss modulus,

$$\delta G''/G'' = \delta (D_s\omega)/(D_s\omega). \quad (10)$$

In turn, the uncertainty in contact stiffness and damping are given by the root-sum-square of the uncertainties in the two comprising terms (see Eqs. 7 and 8).

$$\delta S = [(\delta \kappa)^2 + (\delta \kappa_i)^2]^{1/2} \quad (11)$$

$$\delta (D_s \omega) = [(\delta \chi)^2 + (\delta \chi_i)^2]^{1/2} \quad (12)$$

It is a reasonable approximation to set the uncertainty in the total measured stiffness, κ , to that of the instrument, i.e. $\delta \kappa = \delta \kappa_i$, because for this sort of testing, we expect the total measured stiffness to be dominated by the instrument. We make an analogous observation for the damping, and thus approximate the uncertainties in contact stiffness and damping as

$$\delta S = \sqrt{2} \delta \kappa_i \quad (13)$$

$$\delta (D_s \omega) = \sqrt{2} \delta \chi_i \quad (14)$$

Thus, the first experimental task is to measure $\delta \kappa_i$ and $\delta \chi_i$ over the operating domain of the instrument in order to provide guidance as to the necessary contact radius, available frequency range, and ideal position of the indenter relative to its range of travel.

The size of the frustum is chosen so that the contact stiffness is large (50X) relative to the uncertainty in stiffness. In other words, we wish to select a frustum such that

$$S/(\delta S) > 50; \quad (15)$$

recalling that $S = 8G'\alpha$ (see Eq. 2) and solving for α yields the experimental requirement that

$$\alpha > 50(\delta S)/(8G'). \quad (16)$$

III. Experimental

A. Sample Preparation

All samples were prepared at room temperature of 20-22°C. ThNapFF, shown in Fig. 1, was dissolved in water at a concentration of 5 mg/mL by the addition of 1 molar equivalent of a 0.1

M NaOH solution to a dispersion of the ThNapFF in water. A stock solution of 40 mL was prepared for all the experiments. Solutions were stirred using a magnetic stirrer bar overnight until all the gelator had dissolved.

In all cases, gels were formed by the addition of an aliquot of the stock solution of ThNapFF to GdL (8 mg per mL of stock solution). GdL hydrolyses slowly, so there was sufficient time after addition and mixing to transfer the solution to different moulds prior to gelation, meaning the same gelation trigger and method could be used to prepare samples for all rheological and nanoindentation methods.

For vane-in-cup-rheometry, the gels were prepared in 7 mL Sterilin vials. A pipette was used to add 2 mL of stock solution to the vial into which the GdL had been weighed. The samples were then gently shaken by hand until the GdL had dissolved. The samples were then left for 16 hours to gel before being measured. The Sterilin vials were directly loaded into the rheometer for measurements, so no direct manipulation, transfer or loading of sample was required.

For the nanoindentation measurements and parallel plate measurements, gel samples were prepared in molds using a syringe. This was done by removing the top from 20 mL syringe. GdL (8 mg per mL of stock solution) was added and the sample mixed in a separate vial to make sure all the GdL was dissolved. Care was taken not to generate bubbles in the solution. The solution was then transferred to the syringe which was secured to a flat surface using Blu Tack (Bostik, Leicester, UK). The top was covered with Parafilm to prevent the sample drying out. The samples were then left overnight (around 16 hours) to gel without being disturbed. The gels could then be removed from the mold by removing the Parafilm and gently pushing the plunger. The sample was then removed from the mold using a scalpel to gently removed the gel from the syringe and transferred onto the nanoindentation puck or onto the

bottom plate of the rheometer by using a glass slide and a spatula. Any gels that were damaged in this process were not used.

These methods gave gels formed from the syringe mold (i.e. for nanoindentation and parallel plates) with a diameter of 20 mm and a thickness of around 9 mm (Fig. 2a) and the gels formed in the Sterilin vials (i.e. for vane-in-cup rheology) had a diameter of 12 mm and a thickness of 14 mm (Fig. 2b). All samples were left for 16 hours before mechanical testing.

For confocal imaging, the gelator solution was prepared as before, and 2 μL of a 0.1 wt% of Nile blue in water was added to 1 mL of the stock solution. The stock solution (1 mL) was then mixed with 8 mg of GdL and shaken until dissolved. This solution (100 μL) was immediately transferred to a 35 mm plastic CELLviewTM dish with a glass bottom (Greiner Bio-One). The culture dish was wrapped with a wet paper towel to produce a saturated atmosphere to ensure that the gel did not dry out whilst gelling. The dish was then covered with a lid and sealed with Parafilm and not moved again until imaged so as not to disturb the gelation. These samples gave very thin gels that could be imaged more easily than the bulk samples.

B. Rheometry

All rheological measurements were performed using an Anton Paar Physica 301 rheometer (Anton Paar, Gratz, Austria). Following the manufacturer's instructions, motor and inertia adjustments were made prior to testing. Measurements were carried out at 25°C, maintained using a Peltier plate and water bath. During the experiment, the static force was set to zero and controlled by small automatic adjustments of the fixtures. All measurements were repeated in triplicate to ensure reproducibility of the reported results.

Strain sweeps and frequency sweeps were performed for both vane-in-cup and parallel-plate test configurations. Strain sweeps were carried out from 0.1% to 1000% strain at a frequency of 10 rad s^{-1} (1.6 Hz). The strain at which the gel broke was determined as the point when G' and G'' deviated from linearity, a manifestation of permanent deformation. If indicated, the flow point--the strain at which the sample began to act as a liquid--was determined as the strain at which G'' first exceeded G' . Strain-sweep results are reported in the Supplementary Material. Frequency sweeps were carried out from an angular frequency of 0.02 to 20 Hz (0.1 to 128 rad s^{-1}) at a constant strain of 0.5 %, which was in the linear viscoelastic region determined by the strain sweep.

Vane-in-cup. Vane-in-cup measurements were made with a vane having a cross diameter of 8.8 mm and a length of 10 mm (ST10-4V 8.8/97.5) together with a cup having an aluminum insert to fit a diameter of 14 mm (C-PTD200). The vials holding the prepared gels were loaded directly into the cup of the rheometer and secured using Blu Tack (Bostick, Leicester, UK). The vane was then lowered into the gel sample slowly, using the soft viscoelastic setting to minimize compression during insertion. The vane was completely covered by the gel and was 1.2 mm away from the bottom of the gel.

Parallel-plate. Parallel-plate measurements were made with a sandblasted top having a diameter of 25 mm (PP25/S) and a flat bottom plate having a diameter of 25 mm. Gel disks were carefully transferred to the bottom plate, and the top plate was lowered onto the gel surface slowly, using the soft viscoelastic setting to minimize compression. The gels were measured at a gap distance of 2.6-2.7 mm.

C. Confocal Microscopy

Confocal microscopy images were taken using a Zeiss LSM 710 confocal microscope. The objective was a LD EC Epiplan NEUFLUAR 50x (0.55 DIC). The samples were excited at 634

nm using a He-Ne laser. Multiple part of the gel were imaged to ensure the images were representative of the sample.

D. Nanoindentation

Nanoindentation experiments were conducted with a Nanoindenter G200 system equipped with a DCM-II head (Keysight Technologies, USA). The nanoindenter utilized in this study was similar to the system described by Herbert et al.¹⁷ A flat-ended cylindrical punch having a face diameter of 100 μm (Synton-MDP Ltd, Nidau, Switzerland) was used for all of the experiments. All tests were conducted in a temperature-controlled laboratory with the typical testing temperature being 22°C.

Method for quantifying uncertainties. The first experimental task was to measure the uncertainties in contact stiffness and damping over the operating domain of the instrument. This was accomplished with the indenter “free-hanging,” i.e. not in contact with any sample. A custom test method was designed to perform this characterization which comprised moving the indenter to typical vertical testing positions between +6 μm and +12 μm . Then, at each position, the instrument stiffness and damping were measured at 7 specific frequencies between 15 Hz and 110 Hz. For each position-frequency combination, the instrument stiffness and damping were measured 30 times in succession. Each one of these 30 measurements comprised measuring $(F_0/z_0)\cos \phi$ and $(F_0/z_0)\sin \phi$ over a brief period and averaging over the period to report a single value of κ_i and a single value of χ_i , respectively. The standard deviations of these 30 independent measurements, σ_1 and σ_2 , were used to calculate the relevant uncertainties for that particular position-frequency combination as:

$$\delta S = \sqrt{2}\delta\kappa_i = \sqrt{2} (2\sigma_1), \text{ and} \quad (17)$$

$$\delta (D_s\omega) = \sqrt{2} \delta\chi_i = \sqrt{2} (2\sigma_2). \quad (18)$$

It should be noted that the standard deviations are doubled in order to achieve a 95% confidence interval.

Hydrogel testing. The gels were tested in a custom holder, having a surface area of 25 mm² and a depth of 4 mm. Sequential indents on the gel were separated by at least 200 μ m. The tip was cleaned after each indent to prevent any material being transferred to the subsequent indent location. This was achieved by alternating gel indents with quick indents on a piece of double-sided Scotch tape (3M, MN. USA) mounted on an adjacent sample puck.

Each nanoindentation test on the gel was performed at a particular pre-test compression and a particular frequency. A first series of indents was made wherein the oscillating frequency was fixed at 110 Hz, and the pre-test compression was varied (3-13 μ m). A second series of indents was made wherein the pre-test compression was fixed at 5 μ m and the oscillating frequency was varied (5 Hz - 110 Hz). Each experimental condition (compression-frequency combination) was repeated at three different sites on each of three different gel samples for a total of nine independent indentations per condition.

Each nanoindentation test on the gel comprised two integrated parts: (1) the measurements of the gel, followed immediately by (2) dynamic calibration of the instrument. For the first part of the test, the indenter was brought into full contact with the surface of the gel as indicated by a consistent shift in the phase angle of the displacement oscillation. In order to ensure a consistent phase shift, the phase was monitored over a number of data points to exclude random spikes which would erroneously indicate contact.³⁵ However, once the surface detection requirement was fulfilled, the initial contact was set to the first point in that sequence. Next, the prescribed pre-test compression was applied. Finally, the indenter was vibrated at the prescribed frequency with an oscillation amplitude of 500 nm, and the first terms of Eqs. 7 and 8 were measured. These are the total system stiffness and damping, respectively, from which the instrument contribution had to be measured and subtracted as described next.

The second part of the test--the *in situ* dynamic calibration of the instrument--comprised moving the entire actuator up approximately 1 mm, leaving the indenter column at the test position (the same raw displacement at which the test was conducted) yet not in contact with anything. At this position, the indenter was oscillated at the testing frequency and the response was measured. Specifically, the quantities $(F_0/z_0)\cos \varphi$ and $(F_0/z_0)\sin \varphi$ were averaged over a brief period and recorded for use in Eqs. 7 and 8 for the quantities $(K_i - m_i\omega^2)$ and $(D_i\omega)$ respectively (recall Eqs. 5 and 6 for the case of a free-hanging indenter). By this method, the instrument contribution to the total response was measured as well as possible. Finally, the stiffness and damping were calculated according to Eqs. 7 and 8, and the complex moduli and loss factor were calculated according to Eqs. 2 and 3.

IV. Results and Discussion

A. Nanoindentation Uncertainty

Under most experimental conditions (position-frequency), the uncertainties in contact stiffness and damping were less than 0.1 Nm^{-1} , and under no condition were uncertainties greater than 0.4 Nm^{-1} (Figure 4). The lowest uncertainty was consistently observed at 110 Hz, which is near the resonant frequency of the actuator. This was expected, because this is the condition under which the actuator itself is most dynamically compliant. This observation guided our choice of 110 Hz as the best frequency for performing the series of indents wherein compression was systematically varied (Section IV-B). We did not test above the resonant frequency, because we expected the uncertainties in both stiffness and damping to increase significantly with the dynamic stiffness and damping of the actuator.

As a practical matter, all testing was done with a frustum indenter purchased prior to this analysis, having a radius of $50 \text{ }\mu\text{m}$. However, this uncertainty analysis supports the use of

such a punch to produce an adequate contact stiffness on these gels, which have a shear storage modulus on the order of 20 kPa. Based on our previous work on similar LMWGs, the gels were expected to have a shear modulus of at least 20 kPa.⁹ Recalling that Eq. 16 estimates the needed contact radius required for a 2% relative uncertainty in shear modulus, we used the directly measured uncertainty to calculate

$$a > 50(1.4)(0.1 \text{ N/m})/[8 (20 \text{ kPa})], \text{ or}$$

$$a > 43.8 \text{ } \mu\text{m}.$$

B. Effects of Pre-test Compression by Nanoindentation

We observed slight, but significant, sensitivity to pre-test compression (Figure 5). The relatively large scatter at the smallest pre-test compression of 3 μm indicated incomplete contact between the punch face and the gel surface. For compressions of 5 μm and greater, the storage modulus steadily decreased, while the loss modulus remained constant, effecting a net increase in loss factor. In addition, we noted that the standard deviation was much higher at compressions above 5 μm . These observations guided our choice of 5 μm , or 10% of the punch radius as the best compression to use for the series of varied-frequency indentations. This compression was just large enough to make full contact, yet not so large as to significantly affect the measurements.

The variation in properties with compression may be due to significant violation of the assumption of linear viscoelasticity inherent to the analysis (Eqs. 2 and 3), or due to true material changes, or a convolution of both effects. In PDMS, wherein true material changes with compression are minimal, it is easier to attribute the observed effects of compression to the violation of the assumption of linear viscoelasticity which undergirds the analysis.³⁶ In this work, the assumption of linear viscoelasticity is certainly suspect when the pre-test

compression exceeds 10% of the punch radius. However, with hydrogels that exhibit significant poroelasticity, one might expect compression to cause real changes in the material that are manifest in the measured shear modulus. We lean toward this explanation for decreasing modulus with compression, because the mechanical behavior of poroelastic materials is strongly dependent on fluid flow through the network. Reduced fluid flow has been reported in pre-compressed poroelastic materials.³⁷ In micro-scale indentation experiments on polymeric hydrogels, the modulus was found to decrease slightly with indentation depth, and this was related to the poroelastic response of the materials.^{29, 38} Macro-scale compression of LMWGs has shown that the gel behavior varies depending on the level of strain and the speed of compression, attributed to the movement of fluid in the gels.²⁶

C. Frequency-dependent Properties: Nanoindentation and Rheology

Each method returned self-consistent, albeit different, values for complex modulus (Figure 6, Table I). Nanoindentation returned the greatest values for shear storage and loss modulus, whereas parallel plate rheometry returned the lowest values. However, by every measurement technique, these LMWGs were largely elastic, as manifest by the relatively low loss factor (<0.20) (Figure 6b). Energy added to this gel in testing was substantially returned. Others have observed similar behavior for LMWGs.^{9, 39} The material cause for this elasticity was the mechanical dominance of the fibrous microstructure. Confocal imaging (Figure 7) confirmed that the gels were composed of an evenly dispersed network of very fine fibers. Further, with increasing frequency above 5 Hz, the hydrogel became more elastic (decreasing $\tan \delta$) as the fibrous structure became dynamically stiff.

There are a number of possible reasons for the differences in the absolute values returned by each method. The parallel-plate and vane-in-cup rheometry methods both probe the bulk properties of the LMWG at the scale of about a centimeter. Although the length-scale

is similar for both methods, absolute differences in the measured moduli are expected due to the differing test configurations and associated loading conditions.⁴⁰ The vane-in-cup configuration yielded greater moduli than the parallel plate configuration. The vane-in-cup geometry is generally preferred for LMWGs, because loading the sample into the parallel plate fixtures may weaken the microstructure.²⁵ G'' is very low with the parallel plate configuration relative to the vane setup (more than $4\times$ smaller) suggesting that this is a plausible explanation because G'' is particularly sensitive to a hydrogel's microstructure.⁴¹ Note, in contrast G' is approximately $2\times$ lower with the parallel plates than the vane configuration.

As nanoindentation values (for G' and G'') are significantly higher than those obtained with both vane-in-cup and parallel plate rheometry, the question remains as to whether this is a length-scale effect or related to other factors. When considering G' , length-scale effects seem unlikely here, because confocal imaging shows that nanoindentation with a $100\ \mu\text{m}$ flat punch is 'large' relative to the dense network of fibers, with sub-micron diameters (Figure S2, Supplementary Material). Others have also reported that the elastic modulus returned with nanoindentation for hydrogels is higher than that obtained with bulk measurement techniques.³⁸ Galli et al.³⁸ commented that it is unclear exactly why this trend is observed. Buffinton et al.⁴¹ found significant differences in the elastic modulus of polyacrylamide hydrogels measured with nanoindentation as compared to pipette aspiration and bulk compression. They attributed these to differing loading configurations and the associated flow of water in the gels during the testing. In our case, this may also be a contributory factor for the higher G'' . Relative to rheometry, nanoindentation is an unconstrained test, due to the existence of a large free surface. In response to excitation, fluid moves around the indenter, thus leading to greater energy loss. By comparison, rheometry is more constrained, because the fixtures are large, relative to any free surface. The constraining effect of the fixtures inhibits fluid movement, so that the material behaves more elastically. By analogy, an open-pore, fluid-filled material will manifest

greater damping than a closed-pore version of the same material wherein energy is not dissipated by viscous travel through tight spaces. Differences in absolute values may also be influenced by temporal differences with the techniques, as a single oscillatory nanoindentation test occurs much more quickly (<60 seconds) than a rheometry test (>10 minutes). We further suspect that nanoindentation returns higher G'' , because it causes the least disruption to the microstructure of the gel. Further work is required to conclusively understand the different responses.

Despite absolute differences with each technique, the moduli obtained in this study are in the same order of magnitude and we suggest that oscillatory nanoindentation can be used to complement rheology. It should be noted that hydrogel materials exhibit complex viscoelastic behavior and their properties can be analysed in a number of different ways. However, the advantages and limitations of each technique have to be acknowledged.⁴²

V. Conclusions

We conclude that oscillatory nanoindentation can be used for accurate mechanical characterization of hydrogels as a complementary technique to rheometry. Relative to rheometry, nanoindentation may yield significantly different absolute values for properties, because it probes a smaller volume with a different constraint, but it captures the same trends in mechanical behavior with frequency. Nanoindentation is particularly useful for understanding the influence of localized microstructure on the mechanical behavior of these gels. However, the experimental parameters for oscillatory nanoindentation, especially the radius of the punch face, need to be carefully selected in light of instrument uncertainty. We believe that other nanoindenters of the same make and model will have uncertainties similar to what we have measured here: about 0.1 Nm^{-1} for both instrument stiffness and damping. For

other kinds of nanoindenters, the same uncertainties should be measured by a similar method in order to ensure that those uncertainties are small relative to measured values.

Supplementary Material

Rheometry strain sweep data and additional confocal images can be found in supplementary material.

Acknowledgements

RA is grateful to the Royal Academy of Engineering/Leverhulme Trust for a Senior Research Fellowship (LTSRF1617/13/76). The DCM-II nanoindenter used to conduct this study was funded by a Royal Society grant (RG103629) awarded to RA. We thank Ana María Fuentes Caparrós for collecting the confocal microscope images. The EPSRC are thanked for funding the confocal microscope used in this project (EP/J004790/1 and EP/N007417/1). We thank Finlay Walton (University of Glasgow) for help setting up the confocal microscopy. DJA thanks the EPSRC for a Fellowship (EP/L021978/1), which also funded ERD.

References

1. M.L. Oyen: Nanoindentation of hydrated materials and tissues *Curr Opin Solid St M.* **19**(6), 317 (2015).
2. D. Ebenstein and L. Pruitt: Nanoindentation of soft hydrated materials for application to vascular tissues *J Biomed Mater Res A.* **69**(2), 222 (2004).
3. D.M. Ebenstein and L.A. Pruitt: Nanoindentation of biological materials *Nano Today.* **1**(3), 26 (2006).
4. O. Franke, K. Durst, V. Maier, M. Göken, T. Birkholz, H. Schneider, F. Hennig and K. Gelse: Mechanical properties of hyaline and repair cartilage studied by nanoindentation *Acta Biomater.* **3**(6), 873 (2007).
5. J.M. Shapiro and M.L. Oyen: Viscoelastic analysis of single-component and composite PEG and alginate hydrogels *Acta Mech Sin.* **30**(1), 7 (2014).
6. J.D. Kaufman, G.J. Miller, E.F. Morgan and C.M. Klapperich: Time-dependent mechanical characterization of poly (2-hydroxyethyl methacrylate) hydrogels using nanoindentation and unconfined compression *J Mater Res.* **23**(5), 1472 (2008).
7. M. Oyen: Mechanical characterisation of hydrogel materials *Inter Mater Rev.* **59**(1), 44 (2014).

8. C.T. McKee, J.A. Last, P. Russell and C.J. Murphy: Indentation versus tensile measurements of Young's modulus for soft biological tissues *Tissue Eng Part B: Rev.* **17**(3), 155 (2011).
9. E.R. Draper, L.L.E. Mears, A.M. Castilla, S.M. King, T.O. McDonald, R. Akhtar and D.J. Adams: Using the hydrolysis of anhydrides to control gel properties and homogeneity in pH-triggered gelation *RSC Adv.* **5**(115), 95369 (2015).
10. E.R. Draper, R. Schweins, R. Akhtar, P. Groves, V. Chechik, M.A. Zwijnenburg and D.J. Adams: Reversible Photoreduction as a Trigger for Photoresponsive Gels *Chem Mater.* **28**(17), 6336 (2016).
11. W.C. Oliver and J.B. Pethica: Method for continuous determination of the elastic stiffness of contact between two bodies, (U.S. Patent No. 4,848,141. 18 Jul. 1989).
12. W.C. Oliver and G.M. Pharr: An improved technique for determining hardness and elastic modulus using load and displacement sensing indentation experiments *J Mater Res.* **7**(6), 1564 (1992).
13. J. Hay and E. Herbert: Measuring the Complex Modulus of Polymers by Instrumented Indentation Testing *Exp Techniques.* **37**(3), 55 (2013).
14. S.A. Asif, K.J. Wahl and R.J. Colton: Nanoscale surface mechanical property measurements using force modulation technique. *Abstr Pap Am Chem S.* **217**, U626 (1999).
15. C.C. White, P.L. Drzal and M.R. VanLandingham: Viscoelastic characterization of polymers using dynamic instrumented indentation *Mater Res Soc Symp P.* **841**, 187 (2005).
16. S.A. Hayes, A.A. Goruppa and F.R. Jones: Dynamic nanoindentation as a tool for the examination of polymeric materials *J Mater Res.* **19**(11), 3298 (2004).
17. E.G. Herbert, W.C. Oliver and G.M. Pharr: Nanoindentation and the dynamic characterization of viscoelastic solids *J Phys D Appl Phys.* **41**(7), (2008).
18. C.A. Tweedie and K.J. Van Vliet: Contact creep compliance of viscoelastic materials via nanoindentation *J Mater Res.* **21**(6), 1576 (2006).
19. E.G. Herbert, P.S. Phani and K.E. Johanns: Nanoindentation of viscoelastic solids: A critical assessment of experimental methods *Curr Opin Solid St M.* **19**(6), 334 (2015).
20. K. Moronkeji, S. Todd, I. Dawidowska, S.D. Barrett and R. Akhtar: The role of subcutaneous tissue stiffness on microneedle performance in a representative in vitro model of skin *J Control Release.* **265**, 102 (2017).
21. O. Franke, M. Göken, M. Meyers, K. Durst and A. Hodge: Dynamic nanoindentation of articular porcine cartilage *Mater Sci Eng: C.* **31**(4), 789 (2011).
22. A.E. Peters, E.J. Comerford, S. Macaulay, K.T. Bates and R. Akhtar: Micromechanical properties of canine femoral articular cartilage following multiple freeze-thaw cycles *J Mech Behav Biomed.* **71**, 114 (2017).
23. P. Guglielmi, E. Herbert, L. Tartivel, M. Behl, A. Lendlein, N. Huber and E. Lilleodden: Mechanical characterization of oligo (ethylene glycol)-based hydrogels by dynamic nanoindentation experiments *J Mech Behav Biomed.* **46**, 1 (2015).
24. J. Raeburn and D.J. Adams: Multicomponent low molecular weight gelators *Chem Commun.* **51**(25), 5170 (2015).
25. J. Stokes and J. Telford: Measuring the yield behaviour of structured fluids *J Non-Newtonian Fluid Mech.* **124**(1), 137 (2004).
26. D.J. Adams, L.M. Mullen, M. Berta, L. Chen and W.J. Frith: Relationship between molecular structure, gelation behaviour and gel properties of Fmoc-dipeptides *Soft Matter.* **6**(9), 1971 (2010).
27. L.A. Estroff and A.D. Hamilton: Water gelation by small organic molecules *Chem Rev.* **104**(3), 1201 (2004).

28. P. Terech and R.G. Weiss: Low molecular mass gelators of organic liquids and the properties of their gels *Chemical Rev.* **97**(8), 3133 (1997).
29. Z.I. Kalcioğlu, R. Mahmoodian, Y. Hu, Z. Suo and K.J. Van Vliet: From macro-to microscale poroelastic characterization of polymeric hydrogels via indentation *Soft Matter.* **8**(12), 3393 (2012).
30. I.N. Sneddon: The relation between load and penetration in the axisymmetric Boussinesq problem for a punch of arbitrary profile *Int J Eng Sci.* **3**(1), 47 (1965).
31. G. Pharr, W. Oliver and F. Brotzen: On the generality of the relationship among contact stiffness, contact area, and elastic modulus during indentation *J Mater Res.* **7**(3), 613 (1992).
32. U. Chippada, B. Yurke and N.A. Langrana: Simultaneous determination of Young's modulus, shear modulus, and Poisson's ratio of soft hydrogels *J Mater Res.* **25**(3), 545 (2010).
33. N. Nijenhuis, X. Zhao, A. Carisey, C. Ballestrem and B. Derby: Combining AFM and acoustic probes to reveal changes in the elastic stiffness tensor of living cells *Biophys J.* **107**(7), 1502 (2014).
34. J.-L. Loubet: Some measurements of viscoelastic properties with the help of nanoindentation *NIST SP.* 31 (1996).
35. R. Akhtar, E.R. Draper, D.J. Adams and H. Pfaff: Complex Shear Modulus of Hydrogels Using a Dynamic Nanoindentation Method *C Proc Soc Exp Mech.* 141 (2016).
36. P. Du, C. Cheng, H. Lu and X. Zhang: Extracting viscoelastic properties of soft polymers from dynamic nanoindentation using an improved model, in Solid-State Sensors, Actuators and Microsystems *Transducers & Eurosensors XXVII: The 17th International Conference on*, (IEEE, City, 2013), pp. 1063.
37. K. Jönsson and B.T. Jönsson: Fluid flow in compressible porous media: I: Steady-state conditions *AIChE journal.* **38**(9), 1340 (1992).
38. M. Galli, K.S. Comley, T.A. Shean and M.L. Oyen: Viscoelastic and poroelastic mechanical characterization of hydrated gels *J Mater Res.* **24**(3), 973 (2009).
39. S. Sathaye, A. Mbi, C. Sonmez, Y. Chen, D.L. Blair, J.P. Schneider and D.J. Pochan: Rheology of peptide-and protein-based physical hydrogels: Are everyday measurements just scratching the surface? *Wiley Interdiscip Rev: Nanomed Nanobiotechnol.* **7**(1), 34 (2015).
40. H.-j. Yang, F.-q. Wei, K.-h. Hu, G.-d. Zhou and J. Lyu: Comparison of rheometric devices for measuring the rheological parameters of debris flow slurry *J Mt Sci.* **12**(5), 1125 (2015).
41. V. Adibnia and R.J. Hill: Universal aspects of hydrogel gelation kinetics, percolation and viscoelasticity from PA-hydrogel rheology *J Rheol.* **60**(4), 541 (2016).
42. C.M. Buffinton, K.J. Tong, R.A. Blaho, E.M. Buffinton and D.M. Ebenstein: Comparison of mechanical testing methods for biomaterials: Pipette aspiration, nanoindentation, and macroscale testing *J Mech Behav Biomed.* **51**, 367 (2015).
43. R. Kocen, M. Gasik, A. Gantar and S. Novak: Viscoelastic behaviour of hydrogel-based composites for tissue engineering under mechanical load *Biomed Mater.* **12**(2), 025004 (2017).

Table I. Shear modulus and Tan δ as measured by each technique at 10 Hz. Data are presented as Mean (SD).

Technique/Frequency	G' (kPa)	G'' (kPa)	Tan δ
Vane-in-cup rheology	15.25 (2.87)	1.71 (0.43)	0.11 (0.016)
Parallel plate rheology	7.87 (1.11)	0.39 (0.08)	0.05 (0.004)
Nanoindentation	38.1 (2.87)	8.37 (1.25)	0.22 (0.02)

Figures




Figure 1 Chemical structure of ThNapFF:
(2R)3-Phenyl-2[(2R)3-phenyl-2[2-(5,6,7,8-tetrahydronaphthalen-1-yl)oxy]acetamido]propanamido]propanoic acid .




Figure 2 (a) Nanoindentation sample. Scale bar represents 10 mm. (b) Vane-in-cup rheology sample. Scale bar represents 10 mm.




Figure 3 Images showing (a) LMWG samples formed in the gel mold measured with parallel plate rheometry setup (b) and (c) LMWG gel after a frequency measurement. Scale bar represents 10 mm.




Figure 4 Measurement uncertainty in (a) stiffness (b) damping, conducted with a free-hanging indenter as a function of position and frequency.




Figure 5 (a) G' (b) G'' (c) Loss factor i.e. $\tan \delta$ shown as a function of differing compression applied to the gels with nanoindentation. Error bars represent standard deviation (9 measurements for each pre-compression value).




Figure 6 (a) Complex shear modulus vs. frequency for the LMWG, as measured by nanoindentation and bulk rheometry. (b) $\tan \delta$ vs. frequency for each technique.




Figure 7 Confocal image showing fine fibrous network making up the LMWG microstructure.